

2017-03-28

CPC recommends refusal of this application.

We note the deed document however evidence is required of similar rights for the other plots and not just the 2 mentioned. It still doesn't show ownership of the access road. Additionally we note the new drainage document however it doesn't show Old West Internal Drainage Board rates which are required - needs to refer to 1.1l per second.