My ref: MC

Your ref:

Date: 12th August 2011

Contact:


Direct dial:

0345 045 5212

E Mail:

street.scene@cambridgedshire.gov.uk

Andy Davison
Definitive Map Officer
Box No CC1305
Castle Court
Shire Hall
Cambridge
CB3 0AP





Environment ServicesExecutive Director, Alex Plant

Infrastructure Management & Operations
Box No. ET1030
South & City Area Office
Station Road East
Whittlesford, Cambs
CB22 4NL

Tel: 0345 045 5212 Fax: 01223 833693

Dear Andy

RE: Town and Country Planning Act 1990, s.257 Proposed Diversion of Public Footpath No.18, Sawston

Thank you for your letter dated 4th August 2011 and for the opportunity to comment on the above.

I confirm that we would prefer a tarmac surface to the diverted section of footpath and that maintenance would thus be our responsibility.

The specification would be:

100mm of Granite Sub-base Type 1 60mm of 10-20mm DBM 125p Binder Course 25mm of 6mm DBM 125p Surface Course

Please let me know if you require any further information.

Yours sincerely

Mike (our)

Mike Cooper

Highway Supervisor







